

DRINKING WATER NOTICE

Monitoring or Reporting Requirements Not Met by Appanoose School

The Appanoose School public water supply system violated a drinking water standard. Even though this was not an emergency, as our customers, you have a right to know what happened and what we are doing to correct this situation.

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During December 2009, we did not complete all required monitoring or testing for coliform bacteria and therefore cannot be sure of the quality of our drinking water during that time.

We are routinely required to test for coliform bacteria no fewer than two times a month. Additional samples are required following a coliform-positive or rejected sample. A monitoring violation occurred because of failure to collect one of the routine bacteriological samples required during the month. We only collected one usable routine sample in December 2009.

There is nothing you need to do at this time. Since it is our desire to provide the safest water possible to our consumers, we have taken the action of resumed sampling and begun a closer surveillance of our sampling program and daily record keeping to prevent future violations. We will call our laboratory early in the month if we haven't received bottles needed for sampling.

For information regarding this notice, please contact _____
at Richard Adler 785.566.3396.

Please share this information with all the people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent by Appanoose School. PWS IDs State Lab T0510 EPA KS2105902.
Date distributed February 18, 2010.